



CERTIFICATE OF ANALYSIS - REVISED

Client:	Roxy Peterson	Work Order Number:	343989
Company:	YMCA - John Island Camp - 260041054	PO #:	
Address:	140 Durham Street	Regulation:	O.Reg. 170
	Sudbury, ON, P3E 3M7	Project #:	
Phone:	(902) 300-3812	Fax:	(705) 675-8777
Email:	roxye33pr@gmail.com	DWS #:	260041054
Sampled By:			

Date Order Received:	5/16/2018	Analysis Started:	5/16/2018
Arrival Temperature:	10°C	Analysis Completed:	5/17/2018

TEST RESULTS

Sample Description	Lab ID	Type / Matrix	Date / Time Collected	Field Chlorine		EC	TC
				Free	Total		
Raw Treatment Room	1096718	Raw / Raw Water	5/16/2018 8:36 AM			NDOGT	NDOGT
Treatment Room	1096719	Treated / Treated Water	5/16/2018 8:36 AM			0	0
Kitchen Sink	1096720	Distribution / Treated Water	5/16/2018 8:36 AM			0	0

Result Units: CFU/100mL (water matrix) CFU/g (soil matrix), except HPC which is CFU/1mL. Temp. is in Degrees Celsius.

Note that all tests have been performed in accordance with our accredited and licensed test methods (Method Reference A10 for E. coli, fecal, total coliform and background, and Method Reference A68 for HPC).

REPORT COMMENTS

Lot #1711

Supersedes report printed: 5/17/2018 5:18:30 PM

This report has been approved by:

Khaled Omari, Ph.D.
Laboratory Director

LEGEND

TESTS EC - Escherichia coli, TC - Total Coliforms, FC - Fecal Coliforms, Back - Background, HPC - Heterotrophic Plate Count

RESULTS ~ - No Data. Results Pending.
 INT - Interferences are evident on plate and therefore bacterial colonies cannot be properly counted (interferences can be anything that inhibit the proper growth and formation of target colonies)
 NDOGN - No Data, Overgrown with Non-Target
 NDOGT - No Data, Overgrown with Target
 NDOGHPC - No Data, Overgrown with HPC
 An 'r' after the Lab ID indicates a laboratory replicate.
 Results relate only to the items tested.